Clarifications to the Pre-Bid Queries

Pre-Bid clarifications for "Shifting of BESCOM utilities at ORR from Sarakki Signal to PES College of BMRCL, Package – 1 of Phase-3 Project." in respect of Bid Enquiry No. : **BMRCL/2025-26/EL/WORK_INDENT144** are as follows:

SN	Ref. Clause No	Tender Condition/Qualifying Requirement	Queries Raised/Clarification Sought by the Bidders	Clarification issued by BMRCL
1	Section II - ITT, Clause No. 2.2 (5), Page No.5 of 29	The Bidder / consortium shall source both the DAS & Non-DAS Ring Main Units (RMU) from the manufacturers who meet the following requirements; a. The Manufacturer should have RMU manufacturing unit located in Karnataka and the manufactured RMUs should be in compliance with IP 55 (including control cabinet), tested for IK10 as per IEC 62271-200-1K 10 and should tested for IAC AFLR 21kA for 1 Sec for both tank and cable compartment.	Requested to relax the tender condition regarding RMU manufacturing units located in Karnataka.	Tender condition prevails.
2			Requested to consider IP54 which allows most of the OEMs to participate result in fair competition.	Tender condition prevails.

S N	Ref. Clause No	Tender Condition/Qualifying Requirement	Queries Raised/Clarification Sought by the Bidders	Clarification issued by BMRCL
3		b. The Manufacturer should have a valid vendor approval for the supply of 11KV SF6 Gas Insulated RMU (DAS & Non-DAS) in any ESCOM's of Karnataka. c. The Manufacturer should have supplied 1000 Nos, of RMU's of the following type in last three years to any ESCOM's of Karnataka. • DAS: 3-way, 4 -way & 5-way • Non-DAS: 3-way, 4-way, 5-way, 1 OD d. The Manufacturer shall comply with the technical specifications required in the bid documents.	Requested to consider the RMU Manufacturing vendor approved only in BESCOM and to remove the RMU manufacturing vendors approved in any other utilities/ESCOMs of Karnataka.	Tender condition prevails.

Chief Engineer
Utility Shifting, BMRCL.